

December 17, 2025

Attention: Nicole Kilgore
PRESSURE VESSEL ENGINEERING INC
PO BOX 112
1440 KING STREET NORTH UNIT# 1
ST JACOBS, ON N0B 2N0

The design submission, Tracking Number 2025-07570, Web Portal Number 2025-S6116, originally received on November 25, 2025 was surveyed and accepted for registration as follows:

CRN : 0C25825.2 **Accepted on:** December 17, 2025
Reg Type: NEW DESIGN **Expiry Date:** December 17, 2035
Document No. 22584s-1 Rev 1 As Noted
Fitting type: VALVES

Design registered in the name of : MARSHALL EXCELSIOR COMPANY

Description	MAWP	Design Temperature	MDMT
Internal Pressure	2758kPa	82 °C	-29 °C


The registration is conditional on your compliance with the following notes:

- As indicated on the AB-351 Declaration of Conformity form and submitted documentation, the code of construction is ASME B31.3.
- It is our understanding that the fitting(s), included as the scope of this submission, that is(are) subject to the Safety Codes Act shall comply with the requirements of the indicated Standard or Code of Construction on the AB-351 Declaration of Conformity as supported by the attached data which identifies the dimensions, materials of construction, press./temp. ratings and the basis for such ratings, and the identification marking of the fittings.
- This registration is valid only for fittings fabricated at the location(s) covered by the QC certificate attached to the accepted AB-351 Declaration of Conformity form.
- This registration is valid only until the indicated expiry date and only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency, and maintains a valid Certification of Authorization Permit if required by the jurisdiction where manufacturing takes place, until that date.
- Should the approval of the quality management system lapse before the expiry date indicated above, this registration shall become void.

An invoice covering survey and registration fees will be forwarded from our Revenue Accounts.

If you have any questions don't hesitate to contact me by phone at (587) 686-9381 or fax (780) 437-7787 or e-mail Newton@absa.ca.

Sincerely,



NEWTON, STEPHAN, E.I.T.
DOP Cert. No. D00011044

(Show facsimile of logo or trademark, as it will appear on the fitting as evidence of certification)



**DECLARATION OF CONFORMITY
(Sample Form)
REGISTRATION OF FITTINGS**

2025-07570
ABSA
SAFETY CODES ACT - PROVINCE OF ALBERTA
ACCEPTED: 0C25825.2
See acceptance letter for conditions of registration.
Date: 2025-12-17 By: *M. Stephan*
STEPHAN NEWTON, E.I.T.
DIP. REGISTRATION
This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.

Declaration No.: (document nr. as issued by the manufacturer)	22584sd-01	Revision:	A
--	------------	-----------	---

Manufacturer	(Name and Address) Marshall Excelsior Company Camino a la montaña 186, Colonia Alce Blanco, 53370, Naucalpan de Juárez, Estado de México, México
--------------	--

Table 1 Scope of Fitting Designs

Item No.	Type / Model	Product Description	Material of Construction	MDMT	Rated Pressure		References: Catalog (pages) or Drawing(s)
					At Ambient Temperature	At Maximum Temperature	
1	See	Scope	22584s-1	°C	kPag	kPag at °C	
2				°C	kPag	kPag at °C	
				°C	kPag	kPag at °C	
				°C	kPag	kPag at °C	
				°C	kPag	kPag at °C	

Table 2 Codes, Standards, Guidelines, and Other Applicable Documents

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	ASME B31.3	2024	4		
2			6		
3			6		

Table 3 Quality Program Verification and Manufacturing Sites

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	1500 & 1508 George Brown Drive, Marshall, Michigan, 48068, USA	ISO9001:2015	10/21/2027	DNV
2	Distrito Industrial 108 Colonia Alce Blanco, 53370 Naucalpan de Juárez, Estado de México, México	ISO9001:2015	10/21/2027	DNV
3	1505 Adams Dr., Marshall, Michigan, 48068, USA	ISO9001:2015	10/21/2027	DNV

A copy of the Quality Certificate from each manufacturing site must be included.

Remarks	(other relevant information)
---------	------------------------------

As a senior official of the manufacturer, having responsibility for the conformity and regulatory compliance of the fitting, I hereby declare that the statements made in this declaration of conformity are true and accurate.

I also declare that a conformity assessment has been completed to the extent necessary for validation and verification, and declare that the fitting design and construction are in conformity with the requirements of CSA B51, the applicable codes, and standards and other applicable documents as listed in table 2 of this document.

I further declare that there is a process in place for retention, custody, maintenance, availability, and control of this declaration of conformity, for the duration of a valid Canadian Registration Number and no less than 10 years from the issuance of this declaration of conformity, for the fittings covered by this declaration.

Signed for and on behalf of Marshall Excelsior Company in the _____ of _____
(Manufacturer) (City) (State / Province, Country)

Lisa Meyers, Director of Quality
(Name, please print) (Function or Title)

Lisa Meyers
(Signature of Declarant)

11.19.2025
(Date)



Scope of Registration: 22584s-1 R1
Date: Dec. 10, 2025

Design Code: ASME B31.3, 2024 ed.
Design Pressure: 400 psi
Design Temperature: 180°F – Ductile Iron
100°F – Brass, 12L14
MDMT: -20°F @ 400 psi (for ASTM A536 all grades)
-44°F @ 400 psi (for other materials)
Corrosion: 0, for non-corrosive service
Hydrotest @ ambient: 600 psi @ 70°F
Impact Test: Exempt per 323.2.2
Radiography: None
PWHT: None
Notes: Not for lethal service

Models, sizes, burst and design pressures:

Table with 4 columns: Series, Part Name / Dwg, Material, Burst Test Pressure. Rows include ME840-24-XXX, ME840X-XX, ME840X-X-XX, ME840X-XX-XXX, MEJ400, MEJ402S, ME845XX-X-X, ME846XX-X-X, ME847C-X-X.

Burst Test Report


- Burst Test Report: 17010026

Validation Report/s:

- Calculation Reports: 10733c-1 R1, 22584c-1 R0
FEA Report: 22584f-1 R0

QC Certification

- ISO9001:2015



This stamp and signature have been affixed electronically to this registered design as required by Section 20(1) of the Pressure Equipment Safety Regulation, in accordance with the Electronic Transactions Act.

ATTN: NICOLE KILGORE
PRESSURE VESSEL ENGINEERING
#1 1440 KING STREET PO BOX 112
ST. JACOBS ON N0B 2N0

Date: 17-Mar-2026
TSBC Account #: 061511
TSBC Admin Number: 122064
Canadian Registration Number: 0C25825.21

Re: Application for Design Registration

The design, as detailed in your Design Portal application PVE-22584 for a Pressure Fitting is registered with the following notes and considerations:

Registered To: Marshall Excelsior Company
Project Name: PVE-22584
Drawing #: Scope 22584s-1
Drawing Revision: 1

Conditions of Registration:

(1) Fitting Registration Expiry Date: 16-Dec-2035 (2) The registration is valid until the indicated expiry date only if the Manufacturer maintains a valid quality management system approved by an acceptable third-party agency until that date. Should the approval of quality management system lapse before the expiry date indicated above, this registration shall become void.

Reviewer's Notes:

Any additional conditions and considerations from the initial province of registration shall apply to this BC registration.

Full details of this submission including the scope of registration, design conditions, fabrication details, and calculations pertaining to this design are located in the above Admin Number on the Design Portal. For all other enquiries, please contact eim@technicalsaftybc.ca.

The Engineering Information Management Team

REGISTRATION OF A PRESSURE FITTING DESIGN

January 20, 2026

Pressure Vessel Engineering
1440 King Street N, Unit 1, PO Box 112
St. Jacobs, ON
Canada
NOB 2N0

Attention: Nicole Kilgore

File Number: 104222

Re: Manufacturer: Marshall Excelsior Company
Item: Valves
Catalog or Drawing: Scope of Registration 22584s-1 R1

TSASK Codes and Standards Compliance has registered the design listed above in accordance with The Boiler and Pressure Vessel Act and Regulations and CSA B51. The Canadian Registration Number (CRN) is:

OC25825.23

Expiry Date: 2035-12-17

Please note that every fitting shall be constructed in strict accordance with the registered design.

Fitting registrations are required to be resubmitted for validation after ten (10) years from the registration date in accordance with CSA B51, Clause 4.2.1.

Should you require anything further, please do not hesitate to contact the Codes and Standards Compliance Office at your convenience.

Yours truly,



Liting (Frank) Huang, P.Eng.

Codes and Standards Compliance

Remarks:

A valid quality control program must be maintained at the production facility for the fitting registration to remain valid until the expiry date.

Statutory Declaration (Registration of Fittings)

TSK-1008

I. Declaration Information

I, Lisa Meyers
Director of Quality
(company title, e.g. vice president, plant manager, chief engineer)
(must be in a position of authority in the manufacturing plant where the fitting is produced)
of: Marshall Excelsior Company

In this space, show facsimile of manufacturer's logo or trademark as it will appear on the fitting.



located at: Camino a la montaña 166, Colonia Alce Blanco, 53370, Naucalpan de Juárez, Estado de México, Mexico
(Plant Address -- Apt/Street) (City, Prov) (Postal Code)

do solemnly declare that the fittings listed hereinunder, which are subject to the **Saskatchewan Boiler and Pressure Vessel Safety Act** (check one)

- Comply with the requirements of _____ which specifies the dimensions, Materials of construction, pressure / temperature ratings and identification marking of the fittings, or
(title of recognized North American Standard)
- Are not covered by the provisions of a recognized North American standard and are therefore manufactured to comply with ASME B31.3 2024 ed. as supported by the attached data which identifies the dimensions, materials of construction, pressure / temperature ratings and the basis for such ratings, and the marking of the fittings for identification.

I further declare that the manufacturer of these fittings is controlled by a quality control program which has been verified by the following authority, DNV as being suitable for the manufacturer of these fittings to the stated standard. The fittings covered by this declaration, for which I seek registration, are Bypass Valves

In support of this application, the following information, calculations and / or test data are attached:
See Scope 22584a-1



PAMELA WILLISON
My Commission Expires
July 3, 2030
County of Branch

II. Declaration

DECLARED before me at Marshall Excelsior in the County of Calhoun
this 19 day of November, 2025
Lisa Meyers (print name) [Signature] (Signature)
Pamela Willison (Signature of Commissioner of Oaths)

III. Office Use Only

To the best of my knowledge and belief, the application meets the requirements of the **Boiler and Pressure Vessel Safety Act** and CSA B51, Clause 4.2, and is accepted for registration in Category _____

(Registration Number)

(Date Registered – MM DD YYYY)

(Expiry Date – MM DD YYYY)


(For the Administrator / Chief Inspector)

Technical Safety Authority of Saskatchewan
Registration No. 0C25826.23
File No. 104222
Registered
Date: January 20, 2026
Expiry Date: December 17, 2035
Codes & Standards Compliance Office



Scope of Registration: 22584s-1 R1
Date: Dec. 10, 2025

Design Code: ASME B31.3, 2024 ed.
Design Pressure: 400 psi
Design Temperature: 180°F – Ductile Iron
100°F – Brass, 12L14
MDMT: -20°F @ 400 psi (for ASTM A536 all grades)
-44°F @ 400 psi (for other materials)
Corrosion: 0, for non-corrosive service
Hydrotest @ ambient: 600 psi @ 70°F
Impact Test: Exempt per 323.2.2
Radiography: None
PWHT: None
Notes: Not for lethal service



Models, sizes, burst and design pressures:

Series	Part Name / Dwg	Material	Burst Test Pressure
ME840-24-XXX	3" Bypass Valve	A536 654512	4,505 psi
ME840X-XX	Bypass Valve Without Flanges	A536 604018	
ME840X-X-XX	3/4", 1" Bypass Valve	A536 604018	4,503 psi
ME840X-XX-XXX	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	4,503 psi
MEJ400	Liquid Level Valve	C36000 Brass (ASTM B16 H02 Half-Hard Over 2" Bar)	10733c-1
MEJ402S	Liquid Vent Valve	A320 Cl. 1 B8F	10733c-1
ME845XX-X-X	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	22584c-1/f-1
ME846XX-X-X	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	22584c-1/f-1
ME847C-X-X	1-1/4" Bypass Valve	A536 604018	22584c-1/f-1

Burst Test Report

- Burst Test Report: 17010026

Validation Report/s:

- Calculation Reports:
 - 10733c-1 R1
 - 22584c-1 R0
- FEA Report:
 - 22584f-1 R0

QC Certification

- ISO9001:2015



February 20, 2026

PRESSURE VESSEL ENGINEERING LTD.
1-1440 King St N, PO Box 112
St. Jacob's ON NOB 2N0

Dear Nicole Kilgore,

Re: Reciprocal CRN Registration in Manitoba

As indicated by the Regulatory Reconciliation and Cooperation Table and the Reconciliation Agreement for the Canadian Registration Number (CRN) for Pressure Equipment, the design reviews conducted and accepted by the Canadian province or territory, or their delegated safety authority, will be mutually recognized in the Province of Manitoba. If a registration is conditionally based on compliance with the notes set by the original issuing Jurisdiction, such compliance shall be applied the same to this Province.

Your submission has been registered, as follows:

File Number: 74-R5830
CRN: 0C25825.24
Scope: 22584s-1 Rev 1 As Noted
Manufacturer: MARSHALL EXCELSIOR COMPANY
Expiry Date: 17 December 2035

Along with this letter is the invoice for registration.

In addition, every Pressure Vessel, Boiler, and Heat Exchanger shall be stamped with the registration number and as required by CSA Code B51, a Manufacturer's Data Report (MDR) must be forwarded to this office immediately at the time a unit is shipped to Manitoba. Send your MDR to gasupport@gov.mb.ca. In your subject line, indicate "*Manufacturer's Data Report-CRN No.*" A fee shall be billed to the Manufacturer to process data reports in accordance with the Steam and Pressure Plants Regulation section 17.1.

Please contact gasupport@gov.mb.ca for any questions or concerns.

Inspection and Technical Services

Labour and Immigration
508 – 401 York Avenue, Winnipeg, MB R3C 0P8
T (204) 945-3373 | F (204) 948-2089



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772
www.tssa.org

January 30, 2026

PRESSURE VESSEL ENGINEERING LTD.
1440 KING ST N UNIT 1
ST. JACOBS ON N0B 2N0

Workorder Type: Registration - Fitting(Conventional)
Workorder No: 14898484
Your Reference No.: PVE-22584, Scope 22584s-1
Registered to: MARSHALL EXCELSIOR COMPANY

Dear Nicole Kilgore,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN : 0C25825.25
Main Design No.: Scope of Registration 22584s-1 Rev 1
Expiry Date: Dec 17, 2035

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

Note: Design registration completed under interprovincial agreement with jurisdictional check only.

The stamped copy of the approved registration and the invoice are mailed separately (There will be no hard copies for electronic submissions). Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Ruiming You P,ENG
Engineer, BPV
Tel. : +1 416-734-3428
Email : ryou@tssa.org



Technical Standards & Safety Authority
 345 Carlingview Drive
 Toronto, Ontario
 M9W6N9
 www.tssa.org

DECLARATION OF CONFORMITY REGISTRATION OF FITTINGS

FOR TSSA OFFICE USE ONLY

(Show facsimile of logo or trademark, as it will appear on the fitting as evidence of certification)



This Document has been digitally signed and approved. The stamp size has been optimized for 11 x 17 documents.

Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety Program

REGISTERED

C.R.N.: 0C25025.25

Signed: *Lisa Meyers*

Date: January 30, 2026

Expiry Date: Dec 17, 2035

Declaration No.: (document nr. as issued by the manufacturer)

22584sd-01

Revision:

A

Manufacturer

(Name and Address)

Marshall Excelsior Company

Camino a la montaña 166, Colonia Alce Blanco, 53370, Naucalpan de Juárez, Estado de México, Mexico

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model	Product Description	Material of Construction	MDMT	Rated Pressure		References: Catalog (pages) or Drawing(s)
					At Ambient Temperature	At Maximum Temperature	
	See	Scope	22584s-1	°C	kPag	kPag at °C	
				°C	kPag	kPag at °C	
				°C	kPag	kPag at °C	
				°C	kPag	kPag at °C	
				°C	kPag	kPag at °C	

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	ASME B31.3	2024	4		
2			5		
3			6		

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	1506 & 1508 George Brown Drive, Marshall, Michigan, 46008, USA	ISO9001:2015	10/21/2027	DNV
2	Camino a la montaña 166 Colonia Alce Blanco 53370, Naucalpan de Juárez, Estado de México, Mexico	ISO9001:2015	10/21/2027	DNV
3	1505 Adams Dr., Marshall, Michigan, 49068, USA	ISO9001:2015	10/21/2027	DNV

A copy of the Quality Certificate from each manufacturing site must be included.

Remarks	(other relevant information)
---------	------------------------------

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Marshall Excelsior Company in the Marshall of Michigan, USA
 (Manufacturer) (City) (State / Province, Country)

Lisa Meyers Director of Quality *Lisa Meyers* 01/06/2026
 (Name, please print) (Function or Title) (Signature of Declarer) (Date)



22584s-1 R1

Scope of Registration: 22584s-1 R1
Date: Dec. 10, 2025

THIS IS PART OF CRN
0C25825.25
Technical Standards and Safety Authority
Boilers and Pressure Vessels Safety
Program

Design Code: ASME B31.3, 2024 ed.
Design Pressure: 400 psi
Design Temperature: 180°F – Ductile Iron
100°F – Brass, 12L14
MDMT: -20°F @ 400 psi (for ASTM A536 all grades)
-44°F @ 400 psi (for other materials)
Corrosion: 0, for non-corrosive service
Hydrotest @ ambient: 600 psi @ 70°F
Impact Test: Exempt per 323.2.2
Radiography: None
PWHT: None
Notes: Not for lethal service

Models, sizes, burst and design pressures:

Series	Part Name / Dwg	Material	Burst Test Pressure
ME840-24-XXX	3" Bypass Valve	A536 654512	4,505 psi
ME840X-XX	Bypass Valve Without Flanges	A536 604018	
ME840X-X-XX	¾", 1" Bypass Valve	A536 604018	4,503 psi
ME840X-XX-XXX	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	4,503 psi
MEJ400	Liquid Level Valve	C36000 Brass (ASTM B16 H02 Half-Hard Over 2" Bar)	10733c-1
MEJ402S	Liquid Vent Valve	A320 Cl. 1 B8F	10733c-1
ME845XX-X-X	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	22584c-1/f-1
ME846XX-X-X	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	22584c-1/f-1
ME847C-X-X	1-1/4" Bypass Valve	A536 604018	22584c-1/f-1

Burst Test Report

- Burst Test Report: 17010026

Validation Report/s:

- Calculation Reports:
 - 10733c-1 R1
 - 22584c-1 R0
- FEA Report:
 - 22584f-1 R0

QC Certification

- ISO9001:2015

Montréal, le 30 janvier 2026.

NICOLE KILGORE
PRESSURE VESSEL ENGINEERING LTD.
1-1440 KING STREET NORTH, PO BOX
ST. JACOB'S ONTARIO
CANADA N0B 2N0

Manufacturer : MARSHALL EXCELSIOR COMPANY
1506 GEORGE BROWN DRIVE
MARSHALL MI
U.S.A. 49068

OUR REFERENCE : 940918
Design number : Scope of registration: 22584s-1 Rev. 1
Dated Dec.10, 2025

Subject: Design registration confirmation

Hi,

We wish to inform you that your design registration application has been evaluated and that it was registered under the following Canadian Registration Number (CRN):**0C25825.26**.

The following is a reminder of your obligations regarding certain requirements of the regulation respecting pressure vessels, and the referenced codes and standards:

- The manufacturer must maintain a valid quality control program to manufacture equipment according to the CRN.
- The CRN remains valid as long as there are no changes to the design calculations that might affect the pressure boundary. The design registration of fittings expires 10 years after acceptance. It must, therefore, be resubmitted for validation.
- The manufacturer shall submit a copy of the *Manufacturer's Data Report* to us for each boiler or pressure vessel manufactured according to this CRN within 30 days following the signing of this report.
- The drawing number and the revision number registered under this CRN must be indicated on the *Manufacturer's Data Report* for equipment manufactured according to the CRN.

This notice of approval does not relieve the manufacturer of their responsibilities with respect to the design or fabrication of equipment manufactured according to this CRN.

Yours sincerely,

Direction des équipements sous pression

Montréal

255, boul. Crémazie Est, 2ième étage
Montréal (Québec) H2M 1L5
Téléphone : 514 873-2546
Sans frais : 1 866 262-2084
enregistrementdesplans@rbq.gouv.qc.ca
www.rbq.gouv.qc.ca

Building Act (B-1.1)
Regulation respecting pressure vessels (B-1.1, r. 6.1)
Boiler, pressure vessel, and pressure piping code (CSA B51)



This declaration must be filled out and sent to the Régie du bâtiment du Québec (RBQ) by pressure fitting manufacturers when they make an application registration for fittings.

For more information on the application registration for fittings, consult the www.rbq.gouv.qc.ca/fittings-pv.

1. Fittings to register

List the fittings included in this declaration and that you wish to register.

N°	Description	Additional information (detail, calculations or approval sheets)
1	See scope 22584s-1	
2		
3		
4		
5		

2. Declaration of the person in charge

The person in charge is someone in a position of authority, such as a vice-president, a plant manager or a chief engineer.

2.1 Design

I, the undersigned, Lisa Meyers Director of Quality
(Name of the person in charge) (Title of the person in charge)
from Marshall Excelsior Company, located at Camino a la montaña 166, Colonia Alce Blanco, 53370, Naucalpan de Juárez, Estado de México, Mexico
(Company's name) (Plant's address)

hereby declare that the above-mentioned fittings and subject to the Regulation respecting pressure installations:

comply with the requirements of the ANSI/ASME codes as to their dimensions, identification, material and purpose
or

are not covered by the ANSI/ASME codes, but are in compliance with ASME B31.3 2024 ed.

(Name of code or standard)

code or standard and are designed according to the best current engineering practice, as proven by the enclosed approval report.

2.2 Manufacturing quality control

I further declare that the manufacture of these fittings is controlled by a quality control program that complies with the requirements of the

following code: ISO9001:2015, and has been verified by DNV


(Name of code)

(Authorized agency)


Signature of the person in charge: Lisa Meyers

Date (yyyy-mm-dd): 1-21-2020

3. Declaration of commissioner for oaths

I certify that this declaration has been administered before me, at <u>Marshall Excelsior</u> , on <u>2026-01-21</u> . (Location) (Date (yyyy-mm-dd))	
Signature of commissioner for oaths: <u>Pamela Willison</u>	Date (yyyy-mm-dd): <u>2026-01-21</u>
Stamp the seal: 	

4. Registration confirmation (for RBQ's use only)

As far as I know, this application complies with the requirements of the Act and with standard CSA B51, Part 1, section 4.2, and is accepted for registration in the class _____.	
This registration expires in ten (10) years after the date of registration indicated above, and it must be validated again after this period.	
Canadian registration number (CRN): 	Registration date (yyyy-mm-dd):

Documents to attach

Any application registration for fittings must include these documents:

- Statutory Declaration Registration of Fittings (2 copies)
- Detailed calculations or burst test report (1 copy)
- Detailed technical drawings or catalogues (2 copies)
- Example of the manufacturer's marking (1 copy)
- Proof that a valid and approved quality control program has been implemented (1 copy)
- Form Application for design registration (1 copy)

Sending the form

This declaration is mandatory in order to submit an application registration of fittings.

Application registration for fittings must only be sent by mail to this address:

Bureau d'expertise et d'homologation en équipements sous pression
Régie du bâtiment du Québec
545, boulevard Crémazie Est, 7^e étage
Montréal (Québec) H2M 2V2



Scope of Registration: 22584s-1 R1

Date: Dec. 10, 2025



Design Code: ASME B31.3, 2024 ed.
Design Pressure: 400 psi
Design Temperature: 180°F – Ductile Iron
 100°F – Brass, 12L14
MDMT: -20°F @ 400 psi (for ASTM A536 all grades)
 -44°F @ 400 psi (for other materials)
Corrosion: 0, for non-corrosive service
Hydrotest @ ambient: 600 psi @ 70°F
Impact Test: Exempt per 323.2.2
Radiography: None
PWHT: None
Notes: Not for lethal service

Models, sizes, burst and design pressures:

Series	Part Name / Dwg	Material	Burst Test Pressure
ME840-24-XXX	3" Bypass Valve	A536 654512	4,505 psi
ME840X-XX	Bypass Valve Without Flanges	A536 604018	
ME840X-X-XX	¾", 1" Bypass Valve	A536 604018	4,503 psi
ME840X-XX-XXX	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	4,503 psi
MEJ400	Liquid Level Valve	C36000 Brass (ASTM B16 H02 Half-Hard Over 2" Bar)	10733c-1
MEJ402S	Liquid Vent Valve	A320 Cl. 1 B8F	10733c-1
ME845XX-X-X	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	22584c-1/f-1
ME846XX-X-X	1-1/4", 1-1/2", 2" Bypass Valves	A536 604018	22584c-1/f-1
ME847C-X-X	1-1/4" Bypass Valve	A536 604018	22584c-1/f-1

Burst Test Report

- Burst Test Report: 17010026

Validation Report/s:

- Calculation Reports:
 - 10733c-1 R1
 - 22584c-1 R0
- FEA Report:
 - 22584f-1 R0

QC Certification

- ISO9001:2015


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Marshall Excelsior Company MANUFACTURERS ADDRESS: Camino a la montaña 166, Colonia Alos Blancos, 63370, Huixtla, Estado de México, México PLANT LOCATIONS: Camino a la montaña 166, Colonia Alos Blancos, 63370, Huixtla, Estado de México, México	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY <input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input checked="" type="radio"/> B Flanges: all flanges <input type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies; all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fuel gas plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION: ASME B31.3 2024 ed.
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT 	TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: Bypass Valves See Scope 22584s-1.	

DECLARATION:

I, Lisa Meyers (see note 3) employed by Marshall Excelsior Company, and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV as being suitable for that purpose, and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: [Signature]
 Declared before me at Marshall Excelsior
 This 19 day of November AD 2025
 Commissioner of Oaths or Notary Public: (sign) [Signature]

PAMELA WILSON
 S. E. My Commission Expires 06 FEB 2026
 July 8, 2020
 County of Brimsley
 Acting in the County of Brimsley

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C25825.2</u> FID#: _____ Scope of Registration: 22584s-1 R1, 400 psi (DP); 180F (D), SS - DT), 100F (Br., 12L14 - DT); -20F (D), -44F (other mat.) (DGallant) Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	ACCEPTED PROVINCE OF PRINCE EDWARD ISLAND C.R.N.: <u>0C25825.2</u> DATE: <u>JAN 15 2026</u> SIGNED: <u>[Signature]</u> INSPECTION SERVICES SECTION BOILER/PRESSURE VESSEL BRANCH Sect. 1.0 - Fittings Rev. 1 06/2003


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR


MANUFACTURERS NAME: <u>Marshall Excelsior Company</u>	
MANUFACTURERS ADDRESS: <u>Camino a la montaña 169, Colonia Alca Blanco, 63370, Nautatlan de Juárez, Estado de México, Mexico</u>	
PLANT LOCATIONS: <u>Camino a la montaña 169, Colonia Alca Blanco, 63370, Nautatlan de Juárez, Estado de México, Mexico</u>	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY.</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fuel/oil plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3 2024 ed.</p>
<p align="center">SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div align="center">  </div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p align="center">LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Bypass Valves</p> <p>See Scope 22584s-1</p>	

DECLARATION:

I, Jose Meyers (see note 3) employed by Marshall Excelsior Company and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: [Signature]
 Declared before me at Marshall Excelsior
 This 19 day of November AD 2025
 Commissioner of Oaths or Notary Public: (sign) Pamela Willison


 PAMELA WILLISON
 My Commission Expires
 July 3, 2030
 County of Colchester
 Acting in the County of Colchester

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C25825.2</u> FID#: _____ Scope of Registration: <u>22584s-1 R1, 400 psi (DP); 180F (DI, SS - DT), 100F (Br, 12L14 - DT); -20F (DI), -44F (other mat.) (DGallant)</u> Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	 BOILER & PRESSURE VESSEL NOVA SCOTIA Date <u>Jan. 16/26</u> C.R.N. <u>0C25825.28</u> Dwg. <u>as described</u> Signed <u>[Signature]</u> 1 of 1 Part Sect. 1 & 2 - Fittings Rev. 1 06/2003


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Marshall Excelsior Company	
MANUFACTURERS ADDRESS: Camino a la montaña 100, Colonia Alico Blanco, 63370, Naucalpan de Juárez, Estado de México, Mexico	
PLANT LOCATIONS: Camino a la montaña 100, Colonia Alico Blanco, 63370, Naucalpan de Juárez, Estado de México, Mexico	
<p>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2024 ed.
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	TYPIC TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
	
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: Bypass Valves See Scope 22584s-1	

DECLARATION:

I Lisa Meyers (see note 3) employed by Marshall Excelsior Company and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.


Signature of Declarer: Lisa Meyers
 Declared before me at Marshall Excelsior
 This 19 day of November AD 2025
 Commissioner of Oaths or Notary Public: (sign) Pamela Willison


 PAMELA WILLISON
 My Commission Expires
 July 3, 2030
 Acting in the County of Dothman
 New Brunswick / Nouveau Brunswick

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance. CRN: <u>OC25825.2</u> FID#: _____ Scope of Registration: 22584s-1 R1. 400 psi (DP); 180F (DI, SS - DT), 100F (Br., 12L14 - DT); -20F (DI), -44F (other mat.) (DGallant) Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	DEPT OF JUSTICE PUBLIC SAFETY BOILER & PRESSURE VESSEL ACT REGISTRATION ONLY CRN <u>OC25825.27</u> <u>Pamela Willison</u> CHIEF BOILER INSPECTOR DATE <u>1/16/26</u> Sect. 1.0 - Fittings Rev. 1 06/2003 <input type="checkbox"/> BLRs <input type="checkbox"/> PVS <input checked="" type="checkbox"/> FITTINGS <input type="checkbox"/> NUCLEAR COMPONENTS
--	---

UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS


NEW BRUNSWICK NOVA SCOTIA PRINCE EDWARD ISLAND NEWFOUNDLAND AND LABRADOR
 NUNAVUT YUKON NORTHWEST TERRITORIES

MANUFACTURERS NAME: Marshall Excelsior Company	
MANUFACTURERS ADDRESS: Camino a la montaña 100, Colonia Alca Blanco, 63370, Naucalpan de Juárez, Estado de México, México	
PLANT LOCATIONS: Camino a la montaña 100, Colonia Alca Blanco, 63370, Naucalpan de Juárez, Estado de México, México	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3 2024 ed.</p>
<p align="center">SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div align="center">  </div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p align="center">LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Bypass Valves</p> <p>See Scope 22584s-1</p>	

DECLARATION:

I, Lisa Meyers (see note 3) employed by Marshall Excelsior Company and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: [Signature]
 Declared before me at Marshall Excelsior
 This 19 day of November AD 2025
 Commissioner of Oaths or Notary Public: [Signature]


 PAMELA WILLISON
 My Commission Expires July 0, 2030
 County of Carleton
 Acting in the Colony of Labrador

<p align="center">This space for Regulatory Authority use only</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p align="center">Newfoundland Labrador</p> <p>CRN: <u>OC25825.2</u></p> <p>FIC#: _____</p> <p>Scope of Registration: 22584s-1 R1, 400 psi (DP); 100F (DI, SS - DT), 100F (Br., 12L14 - DT); -20F (DI), -44F (other mat.) (DGallant)</p> <p>Notes:</p> <ol style="list-style-type: none"> All fittings shall be registered in the name of the Manufacturer. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. 	<p>Registered <u>OC 25825.20</u></p> <p>Date <u>Jan 16, 2026</u></p> <p>Engineering and Inspection Services</p> <p>Registered by <u>[Signature]</u></p> <p align="center"> UNDER THE AUTHORITY OF THE PUBLIC SAFETY ACT AND THE BOILER, PRESSURE VESSEL AND COMPRESSED GAS REGULATIONS </p> <p align="right">Rev. 1.0 - Fittings Rev. 1 06/2003</p>
---	--


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Marshall Excelsior Company	
MANUFACTURERS ADDRESS: Camino a la montaña 168, Colonia Añeo Blanco, 53370, Naucalpan de Juárez, Estado de México, Mexico	
PLANT LOCATIONS: Camino a la montaña 168, Colonia Añeo Blanco, 53370, Naucalpan de Juárez, Estado de México, Mexico	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3 2024 ed.</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div align="center" style="border: 1px solid black; padding: 10px; width: fit-content; margin: 0 auto;">  </div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Bypass Valves</p> <p>Sea Scope 22584s-1</p>	


DECLARATION:

I Lisa Meyers (see note 2) employed by Marshall Excelsior Company and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: *Lisa Meyers*
 Declared before me at Marshall Excelsior
 This 19 day of November AD 2025
 Commissioner of Oaths or Notary Public: *Pamela Willison*



PAMELA WILLISON
 My Commission Expires July 9, 2026
 County of Branch
 Acting in the County of Csthan

This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance	
CRN: <u>0C25825.2</u> FID#: _____ Scope of Registration: 22584s-1 R1, 400 psi (DP); 180F (DI, SS - DT), 100F (Br., 12L14 - DT); -20F (DI), -44F (other mat.) (DGallant) Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	 <p>GOVERNMENT OF YUKON BY <u><i>[Signature]</i></u> CRN <u>0C25825.2Y</u> DATE <u>2026/01/19</u> BOILER ROOM BRANCH Sect. 4.0.1.4 (1) (b) 1 06/2003</p>


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: Marshall Excelsior Company	
MANUFACTURERS ADDRESS: Camino a la montaña 166, Colonia Alos Blanco, 53370, Naucalpan de Juárez, Estado de México, Mexico	
PLANT LOCATIONS: Camino a la montaña 166, Colonia Alos Blanco, 53370, Naucalpan de Juárez, Estado de México, Mexico	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p><input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers</p> <p><input type="radio"/> B Flanges: all flanges</p> <p><input checked="" type="radio"/> C Valves: all line valves</p> <p><input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types</p> <p><input type="radio"/> E Strainers, filters, separators, and steam traps</p> <p><input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters</p> <p><input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs</p> <p><input type="radio"/> H Pressure retaining components that do not fall into one of the above categories</p> <p><input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>, (Meeting CNSC or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p>ASME B31.3 2024 ed.</p>
<p align="center">SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div align="center">  </div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/></p> <p>CAST <input type="checkbox"/> OTHER <input type="checkbox"/></p> <p>DESCRIBE OTHER:</p>
<p align="center">LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Bypass Valves</p> <p>See Scope 22584s-1</p>	


DECLARATION:

I Lisa Meyers (see note 3) employed by Marshall Excelsior Company and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Lisa Meyers
 Declared before me at Marshall Excelsior
 This 19 day of November AD 2025
 Commissioner of Oaths or Notary Public: (sign) Pamela Willison



PAMELA WILLISON
 My Commission Expires July 3, 2030
 Acting in the County of Carlson

<p align="center">This space for Regulatory Authority use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>0C25825.2</u></p> <p>FID#: _____</p> <p>Scope of Registration: 22584s-1 R1. 400 psi (DP); 180F (DI, SS - DT), 100F (Br., 12L14 - DT); -20F (DI), -44F (other mat.) (DGallant)</p> <p>Notes:</p> <ol style="list-style-type: none"> All fittings shall be registered in the name of the Manufacturer. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. 	 NORTHWEST TERRITORIES REGISTERED UNDER THE AUTHORITY OF THE BOILER AND PRESSURE VESSEL ACT. C.R.N. <u>0C25825.2T</u> SIGNED <u>Matthew Dymally</u> DATE <u>1/16/26</u>
--	---


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: <u>Marshall Excelsior Company</u>	
MANUFACTURERS ADDRESS: <u>Camino a la montaña 109, Colonia Alto Blanco, 63370, Neocatepan de Juárez, Estado de México, México</u>	
PLANT LOCATIONS: <u>Camino a la montaña 166, Colonia Alto Blanco, 63370, Neocatepan de Juárez, Estado de México, México</u>	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY	TITLE OF THE STANDARD OF CONSTRUCTION
<input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input checked="" type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> . (Meeting CNSC or ASME requirements)	ASME B31.3 2024 ed.
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT	TYPE OF CONSTRUCTION
	FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:	
Bypass Valves See Scope 22584s-1	

DECLARATION:

I, Lisa Meyers (see note 3) employed by Marshall Excelsior Company, and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by PNV as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: [Signature]
 Declared before me at Marshall Excelsior
 This 19 day of November AD 2025
 Commissioner of Oaths or Notary Public: (sign) [Signature]

PAMELA WILLISON
 Notary Public
 July 8, 2025
 County of Belton
 In the County of Belton
 NUNAVUT
 Boilers and
 Pressure Vessels Act

This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0C25825.2</u>	REGISTERED
FID#: _____	CRN <u>0C25825.2N</u>
Scope of Registration: <u>22584s-1 R1. 400 psi (DP); 180F (DI, SS - DT), 100F (Br., 12L14 - DT); -20F (DI), -44F (other mat.) (DGallant)</u>	Date <u>01/16/2026</u>
Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	Signed <u>[Signature]</u> Chief Inspector
Territorial Registration Fee Sect. 1.0 - Fittings Rev. 1 06/2009	