



Certificate of Compliance

Certificate: 80153236

Master Contract: 188848

Project: 80153236

Date Issued: 2023-09-21

Issued To: Marshall Excelsior Company
1506 George Brown Dr
Marshall, Michigan, 49068
United States
Attention: Christine Huckfeldt

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Vajira Sarathchandra
Vajira Sarathchandra

PRODUCTS

CLASS - C333103 - REGULATORS (GAS) LP Gas Low and High Pressure

CLASS - C333183 - REGULATORS (GAS) LP Gas Low and High Pressure-Certified to U.S. Standards

High pressure regulators for LPG applications

Tradename: MEC

<i>Model</i>	<i>INxOUT (F-NPT)</i>	<i>Maximum Outlet Pressure (PSIG)</i>	<i>Maximum Certified Inlet Pressure (PSIG)</i>
MEGR-2104NL/4	1/2"	30	250
MEGR-2104NM/4		50	
MEGR-2104NH/4		125	
MEGR-2106NL/6	3/4"	30	
MEGR-2106NM/6		50	
MEGR-2106NH/6		125	
MEGR-2106NL/8	1"	30	
MEGR-2106NM/8		50	
MEGR-2106NH/8		125	

Note: Operating Temperature Range: -40°F to 55°C

APPLICABLE REQUIREMENTS

ANSI/CAN/UL 144:2021 LP-Gas Regulators (9th Edition, revisions through August 26, 2021)



Supplement to Certificate of Compliance

Certificate: 80153236

Master Contract: 188848

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80153236	2023-09-21	Original certification of high flow pressure regulator series MEGR-2104Nx/4, MEGR-2106Nx/6, MEGR-2106Nx/8, sizes ½", ¾" and 1". (WMTC)