

**ME980-6K
VALVE REPAIR KIT
FOR: ME980 3/4"-1" EMERGENCY
SHUT-OFF VALVE**

!!!WARNING!!!

READ AND UNDERSTAND ALL INSTRUCTIONS INCLUDED WITH THIS REPAIR KIT
RELIEVE ALL PRESSURE FROM SYSTEM BEFORE REMOVING VALVE FOR SERVICE

NOTE: Numbers in brackets [] refer to the number in the valve component list.



WARNING: These products contain a chemical known to the state of California to cause cancer and birth defects or reproductive harm

A. Disassembly

1. **EVACUATE ALL PRESSURE FROM SYSTEM BEFORE ANY DISASSEMBLY OR REPAIR.**
2. Remove Handle Rod [28] and Handle Knob [29] from Handle Body [14] and discard.
3. Remove Release Pin [30] from Body [1] and retain.
4. Remove either Pneumatic Release [31] or Cable Release [32] from Body [1] and retain.
5. Remove Handle Screw [21], Handle Washer [20], Nameplate [19], Nameplate Screw [18], and Nameplate Dial [17] from Handle Body [14] and discard.
6. Remove Handle Body [14] from Stem [3] and discard.
7. Remove Handle Spring [12] from Spring Winder [13] and discard.
8. Remove Spring Winder [13], (2) Thermal Pins [16], and Square Key [15] from Handle Body [14] and discard.
9. Remove (4) Flange Screws [22] from Flange [2] and discard. Retain Flange [2].
10. Remove Flange O-Ring [23], Graphite Seal [24], Valve Seat [26], and Valve Seat Retainer [25] from Flange [2] and discard.
11. Remove Stem Bearing Washer [11], Gland [10], Gland bearing [9], Stem [3], Packing Washer [8], Female V-Packing [7], V-

Packing [6], Male V-Packing [5], and Packing Spring [4] from Body [1] and discard.

12. Remove Clapper Assembly [27] from Body [1] and discard.
13. Inspect Body [1] and clean if necessary, be sure interior is free of dirt, residue and foreign particles.

B. Reassembly

1. Apply suitable lubricant to Male V-Packing [5], V-Packing [6], and Female V-Packing [7].
2. Install Packing Washer [8], Female V-Packing [7], V-Packing [6], Male V-Packing [5], and Packing Spring [4] onto Stem [3].
3. Apply suitable lubricant to bore of Body [1] where Stem [3] is installed.
4. Install Clapper Assembly [27] into Body [1].
5. Install Stem [3] into Body [1] to retain Clapper Assembly [27].
6. Install Gland Bearing [9] onto Stem [3].
7. Apply Anti-Seize to inside of Gland [10].
8. Apply Loctite #271 to threads of Gland [10] and install onto Stem [3] into Body [1], tighten securely.
9. Install Flange O-Ring [23] and Graphite Seal [24] onto Flange [2].
10. Install Valve Seat [26] onto Valve Seat Retainer [25].
11. Apply Loctite #271 to threads of Valve Seat Retainer [25] and install into Flange [2], tighten securely.
12. Install Flange [2] into Body [1].
13. Apply Loctite #271 to (4) Flange Screws [22] and install into Body [1], tighten securely.

Marshall Excelsior Company

1506 George Brown Drive Marshall, MI 49068
Phone (269) 789-6700 Fax (269) 781-8340
www.marshallexcelsior.com

The contents of this publication are for informational purposes only. While every effort has been made to ensure accuracy, these contents are not to be construed as warranties or guarantees, expressed or implied, regarding the products or services described herein or for their use or applicability. Marshall Excelsior Co. reserves the right to modify or improve the designs or specifications of such products at any time without notice. The MEC™ logo is the trademark of Marshall Excelsior Co.

14. Install Stem Bearing Washer [11] onto Stem [3].
15. Install Handle Spring [12] onto Spring Winder [13] and install Spring Winder [13] onto Stem [3].
16. Turn Spring Winder [13] counter clockwise until key slots line up and install Square Key [15] into key slot. Rotate Spring Winder [13] counter clockwise to ensure Clapper Assembly [27] moves freely.
17. Install Handle Body [14] onto Spring Winder [13] with holes aligned.
18. Install (2) Thermal Pins [16] into Handle Body [14].
19. Install Nameplate Dial [17] onto Handle Body [14] with holes aligned.
20. Install Nameplate Screw [18] into recessed hole into Nameplate Dial [17] and tighten.
21. Install Nameplate [19] onto Nameplate Dial [17].
22. Install Handle Washer [20] onto Handle Screw [21]. Apply Loctite #271 to Handle Screw [21] and install into Stem [3], tighten making sure Nameplate [19] still moved freely.
23. Install either the Pneumatic Release [31] or Cable Release [32] into Body [1].
24. Install Release Pin [30] into Body [1] to retain either Pneumatic Release [31] or Cable Release [32].
25. Apply Loctite #271 to threads of Handle Rod [28] and install into Handle Body [14], tighten.
26. Connect the valve assembly outlet to a pressure source of at least 150 PSI. Check for leaks at all joints and stem seals using a suitable leak detector solution such as "Marshall Excelsior" leak detector.

CAUTION: DO NOT USE THE VALVE IF ANY JOINT CONTINUES TO LEAK UNDER PRESSURE.

C. Component List

1. Body
2. Flange
3. Stem
4. Packing Spring
5. Male V-Packing
6. V-Packing
7. Female V-Packing
8. Packing Washer
9. Gland Bearing
10. Gland
11. Stem Bearing Washer
12. Handle Spring
13. Spring Winder
14. Handle Body
15. Square Key
16. Thermal Pin; Qty:2
17. Nameplate Dial
18. Nameplate Screw
19. Nameplate
20. Handle Washer
21. Handle Screw
22. Flange Screw; Qty:4
23. Flange O-Ring
24. Graphite Seal
25. Valve Seat Retainer
26. Valve Seat
27. Clapper Assembly
28. Handle Rod
29. Handle Knob
30. Release Pin
31. Pneumatic Release
32. Cable Release

