

# ME991-16 & ME991-24 2" & 3" NPT BY FLANGE INTERNAL VALVE

# Excelerator

# INSTALLATION AND OPERATING MANUAL

#### !WARNING!

Failure to follow these instructions or to properly install and maintain this equipment could result in an explosion and/or fire causing property damage and personal injury or death.

MEC equipment must be installed, operated, and maintained in accordance with federal, state, and local codes and manufacturer's instructions. The installation in most states must also comply with NFPA No. 58, and ANSI/CGA G-2.1.

For installation in the European Union, the equipment must also comply with PED/TPED and EN ISO standards. Periodic inspections, intermediate inspections and exceptional checks of transportable pressure equipment should be carried out in accordance with the Annexes of Directive 2008/68/EC and with 2010/35/EU Directive (TPED) to ensure continued compliance with their safety requirements.

Only personnel trained in the proper procedures, codes, standards, and regulations of the LP-Gas industry should install and service this equipment.

The internal valve must be closed except during product transfer. A line break downstream of a pump may not actuate the excess flow valve. If any break occurs in the system or if the excess flow valve closes, the system should be shut down immediately.



WARNING: These products contain a chemical known to the state of California to cause cancer and birth defects or reproductive harm

#### Scope of the Manual


This manual covers instructions for the ME991-16 & ME991-24 "Excelerator" Series 2" & 3" NPT BY FLANGE internal valves.

#### Introduction

ME991-16 & ME991-24 Series Excelerator Internal Valves are designed to provide accelerated equalization of tank pressure and downstream line pressure, providing fast valve response time for quick opening. These internal valves may be used as primary shutoff valves, excess flow valves, and back check valves for Propane and NH<sub>3</sub> (anhydrous ammonia) transfers between stationary bulk storage tanks and mobile transports for filling applications of liquid or vapor gas, and on in-line transfer applications. The valves can be used in installations with or without pumps and compressors. Non U.L. listed models are available with a variety of trim types and body styles and can be used on other compressed gases. The installer should check with the factory to make sure the valves

## **Marshall Excelsior Company**

1506 George Brown Drive Marshall, MI 49068 Phone (269) 789-6700 Fax (269) 781-8340 www.marshallexcelsior.com



are suitable for the particular service. Actuation of the valve can be achieved manually, by cable, or with a pneumatic actuator.

#### Features

- Excelerator equalization bleed area Provides high bleed flow for quick opening
- Unique Serviceability Features Accessible stainless steel stem hex and socket drive retaining screws for easy maintenance.
- Durable Design:
  - Stainless poppet and stem with hardened, low friction coating operates smoothly for a long wear life
  - Fully captured main seal and molded-on bleed seal will not "blow-out"
  - Large poppet retaining thread will not break during reverse flow fill
  - Integral travel stop
  - o Stainless steel roller cam
- Excess Flow Closure Functions when flow exceeds the rated capacity of the valve or piping is sheared off at the valve
- Back Check Feature Allows reverse flow filling with or without actuator device in valve open position
- Spring loaded Polytetrafluoroethylene (PTFE) stub shaft packing with auxiliary wiper seals
- Rulon<sup>®</sup> bushings at critical wear points
- Manual, Cable, or Air Open/Close valve actuators
- Thermal Fusible links or plugs melt at 212°F (100°C) and allow valve closure in the event of a fire at the valve

# MEC Europe AsP

Alsvej 21 8940 Randers SV Denmark

The contents of this publication are for informational purposes only. While every effort has been made to ensure accuracy, these contents are not to be construed as warranties or guarantees, expressed or implied, regarding the products or services described herein or for their use or applicability. Marshall Excelsior Co. reserves the right to modify or improve the designs or specifications of such products at any time without notice. The MEC<sup>™</sup> logo is the trademark of Marshall Excelsior Co.

#### Description

Internal valves are typically used on the inlets and outlets of bobtail and transport trucks and on large stationary storage tanks. They can also be installed in-line. Designed for propane or  $NH_3$  at ambient temperatures, the valves can be used on other compressed gases, but the user should check with the factory to make sure the valves are suitable for the particular service and application.

#### **Specifications**

#### Specifications

#### Body Size and End Connection Styles:

Inlet: 2" MNPT (ME991-16), 3" MNPT (ME991-24) Outlet: 2-INCH CL300 RF FLANGE (ME991-16), 3-INCH CL300 RF FLANGE (ME991-24)

#### **Excess Flow Springs**

# Half Coupling Flows:

3" (vertical down): 175, 250, 300, 375, 400, 475 & 500 gpm (662, 946, 1136, 1420, 1514, 1798, 1893 lpm) 2" (vertical down): 110, 160 & 260 gpm (416, 606, 984 lpm)

**Maximum Allowable Inlet Pressure** 

500 psig / 34.5 bar WOG

**Temperature Capabilities** 

-20° to 150°F / -29° to 66°C

#### Approximate weight

ME991-16: 17 pounds / 8 kg ME991-24: 29 pounds / 13 kg

#### DOT Internal Self-Closing Stop Valve Requirement:

U.S. Department of Transportation (DOT) regulations 49CFR§178.337-8(a)(4) require each liquid or vapor discharge outlet on cargo tanks (except for cargo tanks used to transport chlorine, carbon dioxide, refrigerated liquid, and certain cargo tanks certified prior to January 1, 1995) to be fitted with an internal self-closing stop valve. MEC ME991 internal valves comply with the internal self-closing stop valve requirement under the DOT regulations.

#### Installation

#### **Mounting and Piping**

The ME991-16 & ME991-24 Series Internal Valves can be installed in either a half or full coupling or a threaded flange. Excess flow spring closing flow rates vary based on coupling style used, refer to the Specification section.

#### **!CAUTION!**

Excess flow valve closing flow rates are not the same for half and full couplings. Verify the coupling for the desired excess flow rate. Do not install the valve in any piping tending to restrict the valve inlet because this may prevent the excess flow valve from closing.

Do not install the valve with such extreme torque that the coupling can cut threads into the valve. This could cause valve distortion and affect the internal working parts.

# Do not use PTFE tape alone as it may cause thread galling to occur.

Use an appropriate pipe compound, on the male threads of the internal valve and pipeline. Install the valve into the coupling hand tight, and then wrench tighten it for approximately two additional turns. Larger size valves may require an additional amount of torque to obtain a leakfree connection. Keep piping from the valve outlet to the pump full size and as short as possible with a minimum number of bends. Reduction in pipe size to suit smaller pump inlets should be made as close to the pump as possible using forged reducers (swage nipples) or venturi tapers rather than bushings. This assures minimum flow resistance and efficient pump operation. After installation check all joints for leaks using a suitable leak detector solution such as Marshall Excelsior low temp. leak detector before putting the valve into service.

The valves feature a break off section located below the inlet pipe thread which is intended to permit the lower valve body to shear off in an accident, leaving the valve seat in the tank. The break off section is designed for container installations and may not provide shear protection if the valve is installed in a pipeline.

A hydrostatic relief valve does not need to be installed adjacent to the valve since the internal valve relieves excessive line pressure into the tank.

#### Selectively Filling Manifolded Tanks

MEC internal valves provide positive shutoff in only one direction, from out of the tank to downstream of the valve. The internal valves are designed to allow gas to flow into a tank when the downstream line pressure exceeds tank pressure. If you want to selectively fill one or more of the other tanks in a tank manifold system, you must place a positive shutoff valve downstream of the internal valve, otherwise, all tanks will be filled at the same time and at about the same rate.

#### Actuators

The remote operating control system for the internal valve is extremely important, and it must be installed to conform with the applicable codes. DOT MC331, for example, most generally applies for trucks.

MEC offers both cable controls and pneumatic & rotary actuator systems to operate the ME991 internal valves. It

may also be possible to use cable controls from other manufacturers or to fabricate a linkage mechanism.

Any control system requires thermal protection (fuse links) at the valve, at the remote control point and, if necessary, near the hose connections. The instruction manuals for MEC actuator systems show how to install the fuse links.

Installation instructions on MEC MEP650 (Cable Control Mechanism) are in Form #935, ME980-905-25 and ME980-905-50 (Remote Release) are in Form #941. Pneumatic actuator installation is covered in Form #401 and Rotary actuator installation is covered in Form #462. ME991-24 latch/remote release instructions are on Form #934.

The operating linkage must allow the operating lever to move from the fully closed position to within 2° of the fully open position. The linkage should not apply strong force to the lever past the fully open position or the valve could be damaged.

#### Note

The use of non-MEC actuators may result in leakage of the gland packing caused by premature wear. In addition to premature wear, the use of non-MEC actuators may result in lower than expected flow rates and possible leakage across the valve seats.

#### **!CAUTION!**

The internal valve's closing spring is not designed to overcome drag in the control linkage in order to close the valve. Depending upon the control system used, an external spring or positive closing linkage may be needed. Be sure the control system is installed to prevent binding that could cause the valve to stick in the open position.

#### **Excess Flow Operation**

The internal valve contains an excess flow function, or "integral excess flow valve", that is designed to close when the flow exceeds the flow rating established by MEC. MEC integral excess flow valves installed on a bobtail truck or transport can provide protection against the discharge of hazardous materials during an unloading operation of a bobtail truck or transport in the event that the pump or piping attached directly to the internal valve is sheared off before the first valve, pump, or fitting downstream of the internal valve, provided that the cargo tank pressure produces a flow rate greater than the valve's excess flow rating.

Likewise, if the internal valve is installed on a stationary tank or in the related downstream piping system, the integral excess flow valve can provide protection against an unintentional release of hazardous materials in the event that a pump or piping attached directly to the internal valve is sheared off before the first valve, pump, or fitting downstream of the internal valve, provided that the flow of product through the internal valve reaches the rated flow specified by MEC.

#### **!EXPLOSION HAZARD!**

Restrictions incorporated in the discharge system of a bobtail truck or transport or of a stationary tank (due to pumps, pipe and hose length and dimensions, branching, elbows, reductions in pipe diameter, or a number of other in-line valves or fittings), low operating pressure as a result of ambient temperature, or a partially closed valve downstream from the integral excess flow valve, can restrict the rate of flow through the internal valve below the level necessary to actuate the integral excess flow valve. Therefore, <u>DO NOT USE</u> the excess flow function of the internal valve for the purpose of providing protection against the discharge of hazardous materials in the event of a rupture of hose or piping at a point in the discharge system downstream from the first valve, pump, or fitting downstream of the internal valve.

The internal valve is designed with an internal bleed feature for equalization of pressure. After the integral excess flow valve closes, the leakage through the bleed must be controlled or a hazard can be created. For this reason the operator must be familiar with the closure controls for the internal valve and must close the internal valve immediately after the integral excess flow valve closes.

Failure to follow this warning could result in serious or fatal personal injury or property damage from a fire or explosion.

#### DOT Passive Shutdown Equipment Requirement -

DOT regulations 49CFR§173.315(n)(2) require certain cargo tanks transporting propane, anhydrous ammonia and other liquefied compressed gases to be equipped with passive emergency discharge control equipment that will automatically shut off the flow of product without human intervention within 20 seconds of an unintentional release caused by complete separation of a delivery hose. The design for each passive shutdown system must be certified by a Design Certifying Engineer (DCE) and all components of the discharge system that are integral to the design must be included in the DCE certification. The DCE certification must consider any specifications of the original component manufacturer. In the case of downstream ruptures in hose or piping, a variety of operating conditions routinely encountered during an unloading operation restrict the rate of flow through the integral excess flow valve and make such a valve unsuitable to serve as the means of passive shutdown required under 49CFR§173.315(n)(2). Such variables include restrictions incorporated in the discharge system (due to pumps, pipe and hose length and dimensions, branching, elbows, reductions in pipe diameter, or a number of other in-line valves or fittings), low operating

pressure as a result of ambient temperature, or a partially closed valve downstream from the excess flow valve. Due to the variety of conditions, in the case of a hose separation, that can restrict the rate of flow below the level necessary to activate the excess flow valve, the integral excess flow function of MEC ME991 internal valves <u>cannot be used</u> to satisfy the passive shutdown equipment requirement under/in 49CFR§173.315(n)(2). Also, a Design Certifying Engineer <u>cannot include</u> the integral excess flow valve of a MEC ME991 internal valve as a component of the discharge system in any DCE certification under 49CFR§173.315(n)(2).

## **!EXPLOSION HAZARD!**

DO NOT USE the excess flow function incorporated into MEC ME991 internal valves to satisfy the passive shutdown equipment requirement in 49CFR§173.315(n)(2). <u>DO NOT</u> include the excess flow function incorporated into MEC ME991 internal valves in a DCE certification under 49CFR§173.315(n)(2). The cargo tank manufacturer must install some other equipment that satisfies the requirement for passive shutdown capability under 49CFR§173.315(n)(2).

Failure to follow this warning could result in serious or fatal personal injury or property damage from a fire or explosion in the event of an unintentional release of product during an unloading operation.

#### Operation


Since the ME991-16 & ME991-24 Series Internal Valves will not open unless the downstream pressure can build-up to equal the inlet pressure, an operating sequence that assures equalization is important. Follow these steps:

- 1. ME991-16 & ME991-24 on bobtails and transports should never be open when the truck is in motion. If the control system is not interlocked to prevent this, the operator is responsible to ensure that the valves are closed.
- 2. Always open the internal valve before opening any other valves in the line or starting the pump.
- 3. Move the lever to the half-open (rapid equalizing) position to equalize pressure. When the main poppet clicks open, move the operating lever fully open.
- Open other line valves slowly to avoid sudden surges which could slug the excess flow valve shut.
- 5. If the excess flow valve does close, stop the pump and close the nearest downstream valve. Move the internal valve's operating lever back to the rapid equalizing position (outlined in step 3) and wait for the valve to click open. Then move the operating lever fully open and slowly open the downstream valve.

- All valves should be completely open when pumping. (Throttling type valves could prevent the excess flow valve from closing when required.)
- 7. The operator must always be aware of where the remote closure controls are located and know how to operate the controls if an emergency requires valve closure. When pumping is finished, make a habit of closing the internal valve from the remote closure point, thus checking to see that the control actually is capable of closing the valve and operating correctly.
- 8. The valve should be open when backfilling through the valve to fill the tank.

## Troubleshooting

Internal Valve Will Not Open: This could be due to leakage downstream, engaging the pump too soon or from excessive wear in the internal valve. If excessive volume is in the downstream system, a longer time is required to equalize the pressures (tank and downstream) before the pump can be engaged. To determine if the valve pilot seat is opening, install a gauge downstream of the valve, operate the valve actuator; if pressure does not build up to the tank pressure, the valve pilot seat is not open. This test should be done with the pump off. If the pilot is not opening, it may be plugged with dirt or some internal part may be broken. If by operating the lever manually it can be rotated past the fully open position, there is something wrong internally and the valve must be disassembled.



#### Figure 1: Operational Schematic

**Premature Valve Closure**: This can be caused from engaging the pump too soon, by an underrated excess flow valve spring, or by an improperly connected internal valve operating lever which does not fully open the valve. The trouble could also be from a valve that has its inlet port obstructed or from sudden line surges. In order to check the valve opening travel, operate the lever manually to the full travel, wait until valve opens (usually about 15 seconds), then engage the pump. If the excess flow closes, the points mentioned above should be investigated.

Internal Valve Will Not Close: The stub shaft could be binding or the stem could be bent in the valve. Before disassembling the valve, check the actuator mechanism to see that it operates freely by disconnecting it from the valve lever and cycling it several times. Also, operate the valve lever manually. If it sticks in the open position, the packing and bushings should be replaced. This should free the operating mechanism if the valve has not been damaged internally. Refer to the "Maintenance" section.

Low Flow Capacity: This could be caused by an undersized internal valve, undersized or long downstream piping, plugged screens, some other restriction in the downstream system, or by the bypass valve sticking in the open position. The bypass valve could also be set too low and be opening prematurely.

#### **Principle of Operation**

Refer to Figure 1, View #1: the valve is held closed by both tank pressure and the valve's closing spring. There is no leakage past the resilient seats in the poppet to the valve outlet in this position.

The valve is opened by moving the operating lever to approximately midpoint in its 70° travel (figure 1, view #2). This allows the roller cam to place the "Excelerator" equalization portion of the valve stem in the pilot opening, permitting a larger amount of product to bleed downstream than if the operating lever were moved to the full open position.

When tank and downstream pressures have equalized in the bleed position, (after a few seconds), the excess flow spring pushes open the main poppet (figure 1, view #3) and the operating lever can be moved to the full open position.

If tank pressure is greater than the valve's outlet pressure, the main poppet will remain in the closed position. If valve outlet piping is closed off by other valves, however, product bleeding through the pilot will increase until it nearly equals tank pressure and the main poppet opens.

#### Note

#### The main poppet will not open if valve outlet piping is not closed off so that the outlet pressure can approach tank pressure.

Once the main poppet opens, a flow greater than the valve's excess flow spring rating or a sufficient surge in flow forces the main poppet closed against the excess flow spring (figure 1, view #4). The pilot valve allows a small amount of product to bleed, but much less than (figure 1, view #2) where the "Excelerator" equalization portion of the stem is placed in the pilot opening. When the operating lever is moved to the closed position, the valve closes completely and seals tightly (figure 1, view #1).

#### Maintenance

#### **!CAUTION!**

Do not use these internal valves if they leak, fail to work properly or have been damaged or have missing parts. Prompt repairs should be made by a properly trained serviceman. Continued use without repair can create a hazardous situation which could result in serious or fatal personal injury or property damage.

A simple preventative maintenance program for the valve and its controls will eliminate many potential problems.

MEC recommends these steps be conducted once a month. Also refer to the Department of Transportation (DOT) CFR 49 Sections 180.416 and 180 Appendix A and B which specify monthly maintenance and inspections tests for cargo tank service internal valves and their actuation controls.

- Inspect the operating lever to see that it operates freely and that there is no leakage around the retainer nut. If there is sticking or leakage, replace the packing and bushings.
- 2. Check for tight closure of the seat seals. Any detected leakage, which is normally caused by seal wear or dirt, scale or debris embedded in the seal, requires that the internal valve be removed from service and repaired. Repair most often requires the replacement of valve seals. To check for leakage:
  - a. Close the internal valve and exhaust downstream pressure. Close the first valve downstream from the internal valve, and note any pressure buildup, using a pressure gauge, between the closed valve and the internal valve. If piping is cold, allow it to warm to ambient temperature.
  - b. Refer to CFR 49 Section 180 Appendix B for Meter Creep Test Methods.
- All operating controls should be inspected, cleaned and oiled. The controls should be checked to see that they fully open but not over travel the internal valve operating lever and operate freely to close the valve.
- Standard construction internal valves must be removed if the container is to be steam cleaned. Heat can damage the valve's seats and seals.
- Standard construction internal valves are not designed for water service. Immediately after a container is hydrostatically tested, remove all water and allow the container to thoroughly dry out.

#### **Parts Ordering**

#### Important

Use only genuine MEC replacement parts. Components that are not supplied by MEC should not, under any circumstances, be used in any MEC valve, because they might adversely affect the performance of the valve, and could give rise to personal injury and property damage.


When corresponding about this equipment, always reference the equipment model number or series number found on the nameplate.

Valve	ME991-16	ME991-24		
Available Service Kit	ME990-16-SRK	ME990-24-SRK		
	ME990-16-VRK	ME990-24-VRK		
	ME990-PGA			
	ME990-PRK			


SRK – Seal Repair Kit VRK – Valve Repair Kit PGA – Packing Gland Assembly PRK – Packing Repair Kit


See parts list for corresponding parts and service kit components.

Parts List For ME991-16			ME990-					
Ref.#	Description	Qty.	16-SRK	16-VRK	PGA	PRK		
1	Body, Ductile Iron	1						
2	Stem	1		✓				
3	Valve Poppet	1		√				
	Ex. Flow Spring, Yellow, 110 GPM							
4	Ex. Flow Spring, Green, 160 GPM	1						
	Ex. Flow Spring, Blue, 260 GPM							
5	Main Valve Seal	1	✓	✓				
6	Seal Retainer	1		✓				
7	Guide Bushing	1	✓	✓				
8	Guide, Plated Steel	1		✓				
9	Spring Seat	1		✓				
10	Closing Spring	1		✓				
10	Valve Poppet Screw	4		· ✓				
12	Bleed Disc, Nitrile	1	✓	✓ ✓				
12	Lock Nut	1	•	✓ ✓				
15	Cotter Pin	1		✓ ✓				
14		1	✓	✓ ✓	✓	~		
16	Gland O-Ring, Nitrile	1	•	✓ ✓	•	•		
	Upper Washer			▼ ✓				
17	Lower Washer	1		v				
18	Nameplate	1						
19		1						
20	1/4" NPT Plug	1						
21	Nameplate Screw	2						
22	Gland Assembly, Nitrile	1		✓	✓			
22A	Stub	1						
22B	Bonnet	1						
22C	Wiper, Nitrile	1	✓			<b>√</b>		
22D	Gland Bushing	2	✓			✓		
22E	Nylon Washer	1	✓			$\checkmark$		
22F	Female Adapter	1	✓			$\checkmark$		
22G	V-Pack	3	✓			$\checkmark$		
22H	Male Adapter	1	✓			$\checkmark$		
22J	Thick Washer	1						
22K	Gland Spring	1						
22L	Thin Washer	1						
22M	Gland	1						
22N	Spring Pin	1	✓			$\checkmark$		
22P	O-Ring, Nitrile	1	✓			✓		
22Q	Cam	1						
22R	Rivet	1						
22S	Roller Bushing	1						
22T	Roller	1						
23	Cotter Pin / Valve Link	1		$\checkmark$				
24	Stem O-Ring, Nitrile	1						
25	Stud	8						
26	Flange Nut	8						
27	Flange Gasket	1						



Parts List For ME991-24			ME990-					
Ref.#	Description	Qty.	24-SRK	24-VRK	PGA	PRK		
1	Body, Ductile Iron	1						
2	Stem	1		√				
3	Valve Poppet	1		✓				
4	Spring Seat	1		✓				
5	Closing Spring	1		✓				
6	Main Valve Seal	1	✓	✓				
7	Lock Washer	6		✓				
8	Seal Retainer	1		✓				
9	Valve Poppet Screw	6		· ✓				
10	Bleed Disc, Nitrile	1	✓	· ✓				
10	Lock Nut	1		· •				
12	Cotter Pin	1		· ✓				
12			✓	· ✓	✓	~		
13	Gland O-Ring, Nitrile	1	v	▼ ✓	v	v		
	Upper Washer	1		✓ ✓				
15	Lower Washer	1						
16	Guide Bushing	1	✓	<ul> <li>✓</li> </ul>	ļ			
17	Guide	1		✓	ļ			
	Excess Flow Spring, Purple, 175 GPM	4						
	Excess Flow Spring, Black, 250 GPM	1						
	Excess Flow Spring, Yellow, 300 GPM							
18	Excess Flow Spring, Yellow, 375 GPM	1						
	Excess Flow Spring, Red, 400 GPM							
	Excess Flow Spring, Silver, 475 GPM							
	Excess Flow Spring, Gold, 500 GPM	1						
19	Lever	1						
20	Nameplate	1						
21	Fusible Link	1						
22	Gland Assembly, Nitrile	1		✓	✓			
22A	Stub	1						
22B	Bonnet	1						
22C	Wiper, Nitrile	1	✓			✓		
22D	Gland Bushing	2	✓			$\checkmark$		
22D 22E	Nylon Washer	1	· •			· •		
22L 22F	Female Adapter	1	· ✓			• •		
			✓ ✓			• ✓		
22G	V-Pack	3						
22H	Male Adapter	1	$\checkmark$			✓		
22J	Thick Washer	1						
22K	Gland Spring	1						
22L	Thin Washer	1						
22M	Gland	1						
22N	Spring Pin	1	✓			✓		
22P	O-Ring, Nitrile	1	✓			$\checkmark$		
22Q	Cam	1						
22R	Rivet	1						
225	Roller Bushing	1						
22T	Roller	1						
23	Cotter Pin / Valve Link	1		√				
	1/4" NPT Plug	1						
24	1/4 INFI FIUS	1 -						
		2						
25	Nameplate Screw	2	✓	✓				
25 26	Nameplate Screw Stem O-Ring	1	~	~				
25 26 27	Nameplate Screw Stem O-Ring 1 1/4" Steel (Key) Ring	1 1	✓ 	✓ 				
25 26	Nameplate Screw Stem O-Ring	1	✓ 	✓				





**Gland Assembly**